

**Office of the Joint Director Fire & Emergency Services  
Jammu Range, Jammu**

**The Principal  
Govt. College of Education  
Canal Road, Jammu**

No: JDJF&ES/FP/ 4170

Sub: Provisional Fire Safety Certificate.

Dated: 23.09.2020


Ref: Your Letter No. GCOE/J/2020/947 dated: 24.08.2020.

Sir,

The inspection of above said college was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their building premises at present. The site is about 03 Km away from Fire & Emergency Station Kathua and is approachable for fire appliances in case of any emergency. Since the college is already functioning as such, the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures in letter and spirit forthwith:--

1. 10 Nos. ABC Type Fire Extinguishers of 04 Kg. capacity each should be provided in the college premises at strategic locations and 02 Nos. of CO<sub>2</sub> Type fire extinguisher of 4.5 Kg capacity each should be provided near each main electric switch board panel.
2. Manual operated Fire Alarm System should be provided in the building for alerting inmates in case of any emergency.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. First Aid Fire fighting system installed in building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments installed in the building are functioning.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside college premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
8. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
9. The management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present college is having five blocks in which four are double storied & one is single storied. As such, no addition / alteration should be made by the management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
11. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
12. The validity of this provisional clearance shall remain enforce for six months and same needs to be renewed after checking of fire fighting system installed in the buildings (i.e. existing as well as proposed).

Yours Sincerely

  
Joint Director  
Fire & Emergency Services  
Jammu Range, Jammu